

6.98

$$\text{COP}_R = \frac{T_L}{T_H - T_L} = \frac{265}{33} = 8.03$$

$$\dot{W}_{\min} = \frac{\dot{Q}_c}{\text{COP}_R} = \frac{300 \text{ kJ/min}}{8.03 \times 60} = 0.623 \text{ kW}$$

6.103

$$\text{COP}_{HP} = \frac{T_H}{T_H - T_L} = \frac{295}{20} = 14.75$$

$$\dot{W}_{\min} = \frac{\dot{Q}_H}{\text{COP}_{HP}} = \frac{110,000 \text{ kJ/h}}{14.75} \times \frac{1}{3600 \text{ s/h}} = \underline{2.07 \text{ kW}}$$

6.110

$$\text{COP}_{HP} = \frac{T_H}{T_H - T_L} = \frac{298}{28} = 16.3$$

$$\dot{Q}_H = (\dot{Q}_H)(24) = (82,000)(24) = 1,968,000 \text{ kJ}$$

$$\dot{W} = \frac{\dot{Q}_H}{\text{COP}_{HP}} = \frac{1,968,000 \text{ kJ}}{16.3} = 120,763 \text{ kJ}$$

$$\Delta t = \frac{W}{\dot{W}} = \frac{120,763 \text{ (kJ)}}{8 \text{ kJ/s}} = 15,092 \text{ s} = \underline{4.19 \text{ h}}$$

$$(b) \text{ Cost: } (8 \text{ kW})(4.19 \text{ h}) \times \$0.085/\text{kWh} = \$2.85/\text{day}.$$

$$(c) (1,968,000 \text{ kJ}) \left(\frac{1 \text{ kWh}}{3600 \text{ kJ}} \right) (\$0.085) = \underline{\$46.47}$$

6-113 R-134a

$P = 500 \text{ kPa}$, sat. vapor

$h = 259.30 \text{ kJ/kg}$

$v = 0.04112 \text{ m}^3/\text{kg}$

$P = 1.2 \text{ MPa}$) SH

$T_2 = 50^\circ\text{C}$

$h = 278.27 \text{ kJ/kg}$

$$\dot{m}_R = \frac{V_1}{v_1} \text{ (at the Comp. inlet)}$$

$$= (100 \text{ l/min}) \left(\frac{.1}{1000 \text{ l}} \right) \left(\frac{1 \text{ min}}{60 \text{ s}} \right)$$

$$= 0.0405 \text{ kg/s}$$

$$\dot{W}_{in} = \dot{m}_R (h_2 - h_1) = (0.0405)(278.27 - 259.3) = 0.769 \text{ kW}$$

$$\dot{Q}_L = \frac{(250)}{60} \text{ kW} + 0.9 = 5.067 \text{ kW}$$

$$\text{COP} = \frac{\dot{Q}_L}{\dot{W}} = \frac{5.067}{0.769} = 6.59$$

$$\text{COP}_{R, \text{max}} = \frac{T_L}{T_H - T_L} = \frac{299}{8} = 37.4$$

$$\dot{W}_{min} = \frac{\dot{Q}_L}{37.4} = \frac{5.067}{37.4} = 0.136 \text{ kW}$$

Minimum Refrigerant flow rate is the same as above.

6.122 $V_{air} = \frac{(0.6)}{2} (\text{8/day}) (365) = 876 \text{ m}^3/\text{yr}$

$$\rho_o = \frac{P_o}{R T_o} = \frac{95}{(0.28)(277)} = 1.2 \text{ kg/m}^3$$

$$\dot{m}_{air} = \rho V = (876)(1.2) = 1051.2 \text{ kg/yr}$$

(3)

$$\text{Moisture} = \frac{1051 \times 0.006}{6.306 \text{ kg/year}}$$

$$Q_{\text{gain}} = Q_{\text{sensible}} + Q_{\text{latent}}$$

$$Q_{\text{Total}} = 32,500 \text{ kJ/year}$$

$$\dot{W} = \frac{Q}{\text{COP}} = \frac{32,500}{1.4} = 6.5 \text{ kwh/yr.}$$

$$\text{Cost} = \frac{6.5 \times 0.075}{\$0.48/\text{yr}}$$

(16) Same as above except for latent.

$$\frac{151}{\text{m}^3} \dot{m}_{\text{water}} = (0.4)(20)(1) = 8 \text{ kg/hr.}$$

$$\text{Sensible load: } (8)(4.18)(22-8) = 468 \text{ kJ/h} \\ = \underline{130 \text{ W}}$$

$$Q_{\text{gain}} = 45 \text{ W}$$

$$Q_{\text{Total}} = 130 + 45 = 175 \text{ W}$$

$$\text{COP}_R = 2.9$$

$$\dot{W}_{\text{ref}} = \frac{\dot{Q}_{\text{ref}}}{\text{COP}} = \frac{175 \text{ W}}{2.9} = \underline{\underline{60.3 \text{ W}}}$$

$$\frac{159}{\text{m}^3} \dot{Q}_H = \dot{m} c_p (\Delta T)$$

$$= \left[\frac{(0.02) \text{ m}^3}{60 \text{ s}} \right] \times \frac{1}{0.001 \text{ (m}^3/\text{kg)}} (40^\circ \text{C}) \times (418)$$

$$\text{COP}_{\text{HP}} = \frac{T_H}{T_H - T_L} = \frac{303}{30} = \underline{\underline{10.1}}$$

$$\dot{W}_{\text{in}} = \frac{Q}{\text{COP}} = \frac{55.7}{10} = \underline{\underline{5.57 \text{ kW}}}$$